



Pole, aluminum round tapered. Invisible welded longitudinal seam. Alloy 6063-T6 satin ground finish.

Arm - 2" aluminum pole alloy 6063-T6 satin ground finish.

Complete with 4" x 6" reinforced hand hole cover, bolt-on shaft cap, anchor bolts, anchor bolt covers, hardware and anchor bolt circuit template.

Provide the pole from the following manufacturers only:

1. HAPCO #21-297 or approved equal interchangeable with same weight per foot, taper per foot, hole patterns, and metal thickness.

Mount photocontrol atop pole cap of first pole from service disconnect. Face cell due north. Photocontrol shall be General Electric #CRI74H651 with top adapter No. C403G010 or approved equal interchangeable. Run 3 #12 USE to lighting contactor at service disconnect.

NOTE: Where "approved equal interchangeable" is called for in these specifications it shall be construed to mean that parts will interchange with the parts called for without the need for modifications or adapting devices. Approval shall be by the City Engineer and the Street Department for Grove City, Ohio.

APPROVED
EVANS, MECHWARTZ, HAMBLETON & TILTON, INC.

By

Alan E. Korman
Charles H. Good, Jr.

CITY ADMINISTRATOR

STREET LIGHTING
POLE DETAIL

CITY OF
GROVE CITY, OHIO

STANDARD
CONSTRUCTION DRAWING

REV.
8-21-87

DATE

DWG. NO
C-GC-35