



1. SEWER PIPE WILL BE SECURED THROUGH THE MANHOLE WALL BY "KOR-N-SEAL" BOOT, "PRESS WEDGE II" GASKET, OR AN APPROVED EQUIVALENT.
2. ALL CONSTRUCTION AND MATERIALS SHALL CONFORM TO ASTM SPECIFICATION C478-70, UNLESS OTHERWISE SHOWN.
3. ALL CONCRETE SHALL BE CLASS C.
4. FIELD CUT OPENINGS SHALL BE DONE ONLY AS DIRECTED BY THE ENGINEER.

APPROVED  
 EVANS, MECHWART, HAMBLETON & TILTON, INC.

By *Charles W. Broad*  
 CITY ADMINISTRATOR

**PRECAST  
 CONCRETE PIPE  
 MANHOLE**

CITY OF GROVE CITY, OHIO		
STANDARD CONSTRUCTION DRAWING		
REV. 11-17-93	DATE	DWG. NO. C-GC-3