



NOTES:

1. Stub house underdrain into ADS Tee and match existing house underdrain diameter, use reducer if existing drain is less than 4".
2. The roof drain pipe shall be encased where it crosses underneath the sidewalk. The concrete encasing shall be 12" deep below finished sidewalk grade and 12" wide.
3. A contraction joint is to be tooled in sidewalk panel directly above roof drain. The pipe shall be encased in 8" of Columbus Class "C" concrete beneath the sidewalk.
4. The cap shall be left exposed and no more than 1" above finished grade.

Approved By:

[Signature]

City Engineer, EMH&T Inc

[Signature]

City Service Director

STANDARD DIMENSIONS
FOR

**RESIDENTIAL
UNDERDRAIN
JUNCTION BOX**

**CITY OF
GROVE CITY, OHIO**

STANDARD
CONSTRUCTION DRAWING

Revised		Drawing No.
October 2015		C-GC-78A