

TYPE IV


PAVEMENT SECTION ITEMS

- ① Item 304 - Aggregate Base, T = 6-in, (or Equal)
- ② Item 448 - Asphalt Concrete, Type 1, T = 2-in - OR - Item 405 - Bituminous Cold Mix, T = 2-in

DETAIL NOTES

1. Trench width, "W", shall be as shown on the applicable pipe trench, bedding, and backfill standard drawing (C-GC-26).
2. Unless otherwise specified, payment limit for temporary replacement shall be W + 1-ft.
3. No recycled Portland Cement Concrete will be permitted for the trench backfill.
4. When Flowable Controlled Density Backfill (FCDF, per Columbus CMS Item 613) is used, Item 304, Aggregate Base shall be omitted.
5. When trench is less than 2-ft from an adjacent curb, the pavement replacement limit shall be extended to the curb.
6. Temporary pavement shall be placed on the same day that the original pavement is cut.

Approved By:

 City Engineer, EMH&T Inc

 City Service Director

STANDARD DIMENSIONS
 FOR
**PAVEMENT
 REPLACEMENT
 (TEMPORARY)**

CITY OF GROVE CITY, OHIO		
STANDARD CONSTRUCTION DRAWING		
Revised		Drawing No.
Rev February 2016		C-GC-69