



**NOTES:**

1. Curb or combined curb and gutter shall be taken out and replaced with concrete separated from the ramp by 1/2-in pre molded expansion joint. When less than 5-ft of a curb section remains after the curb cut is located, it shall also be removed and replaced. New curb shall be constructed in min. 5-ft sections and max. 10-ft sections.
2. Fills, if required, shall be of earth compacted in 2-in layers, or if Item 304, subbase compacted in layers not exceeding 4-in.
3. Shared-use shall be constructed of portland cement concrete, 5% to 8% air entrained, Columbus Class COC 5 per Item 499.
4. Expansion joints shall be placed to form utility strips where required and wherever new concrete touches existing construction.
5. Forms consist of 2-in nominal thickness wood or metal of equal strength.
6. All construction and materials shall conform to the city of Columbus Construction and Material Specifications (CMSC), latest edition, unless noted otherwise.
7. Shared-use paths shall meet the most current specifications of the ADA Accessibility Guidelines (ADAAG).
8. Contractor shall apply a cure & seal compound, as approved by the City, to finished concrete immediately after finishing.
9. Detectable Warning Surface per C-GC-43DW

Approved By:  
  
 City Engineer, EMH&T Inc  
  
 City Service Director

STANDARD DIMENSIONS  
 FOR  
**STANDARD  
 SHARED-USE PATH  
 RAMP**

<b>CITY OF GROVE CITY, OHIO</b>		
STANDARD CONSTRUCTION DRAWING		
Revised	Sheet	Drawing No.
February 2019		<b>C-GC-83</b>