



**TYPE IV**

**PAVEMENT SECTION ITEMS**

- ① Item 304 – Aggregate Base, T = 6-in, (or Equal)
- ② Item 441 – Asphalt Concrete, Type 1, (448) T = 2-in – OR –  
Item 405 – Bituminous Cold Mix, T = 2-in

**DETAIL NOTES**

1. Trench width, "W", shall be as shown on the applicable pipe trench, bedding, and backfill standard drawing (C-GC-26).
2. Unless otherwise specified, payment limit for temporary replacement shall be W + 1-ft.
3. No recycled Portland Cement Concrete will be permitted for the trench backfill.
4. When Low-Strength Mortar Backfill (LSMB, per Columbus CMS Item 613) is used, Item 304, Aggregate Base shall be omitted.
5. When trench is less than 2-ft from an adjacent curb, the pavement replacement limit shall be extended to the curb.
6. Temporary pavement shall be placed on the same day that the original pavement is cut.
7. When temporary trench repair impacts pavement markings, contractor shall install temporary pavement markings per Item 614.11.

Approved By:  
  
 City Engineer, EMH&T Inc  
  
 City Service Director

STANDARD DIMENSIONS  
 FOR  
**PAVEMENT  
 REPLACEMENT  
 (TEMPORARY)**

**CITY OF  
 GROVE CITY, OHIO**

STANDARD  
 CONSTRUCTION DRAWING

Revised		Drawing No.
February 2019		C-GC-69