



**NOTES:**

1. For city-owned utilities that are located at a depth of less than 5-ft, the minimum setback distance (from the nearest part of the pole or foundation to the nearest outside edge of the utility pipe) shall be a minimum of 3-ft.
2. For city-owned utilities that are located at a depth of 5-ft or greater, the minimum setback distance shall be determined by the following formula:

$$x' + 3' = \text{Minimum Setback Distance}$$

Approved By:  
  
 City Engineer, EMH&T Inc  
  
 City Service Director

STANDARD DIMENSIONS  
 FOR  
**WIRELESS  
 COMMUNICATION  
 UTILITY SETBACK**

<b>CITY OF GROVE CITY, OHIO</b>		
STANDARD CONSTRUCTION DRAWING		
Revised		Drawing No.
February 2019		C-GC-99D